

Radon Testing Results - Crane High School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
CRANE HIGH SCHOOL	ADMIN	ADMIN OFFICES	9545322	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	AG BUILDING	SHOP	9545444	12/8/2020	Detector Kit	0.5
CRANE HIGH SCHOOL	AG BUILDING	DAVIS OFFICE	9545699	12/8/2020	Detector Kit	0.3
CRANE HIGH SCHOOL	AG BUILDING	DAVIS CLASSROOM	9545700	12/8/2020	Detector Kit	0.3
CRANE HIGH SCHOOL	DORMS	DORM 11	9538377	12/8/2020	Duplicate	0.9
CRANE HIGH SCHOOL	DORMS	DORM 12A	9538378	12/8/2020	Duplicate	0.8
CRANE HIGH SCHOOL	DORMS	DORM 17	9538397	12/8/2020	Detector Kit	1.7
CRANE HIGH SCHOOL	DORMS	DORM ROOM 13	9545425	12/8/2020	Detector Kit	2.8
CRANE HIGH SCHOOL	DORMS	DORM 14 BEDROOM	9545426	12/8/2020	Blank	0.3
CRANE HIGH SCHOOL	DORMS	DORM ROOM 15	9545427	12/8/2020	Duplicate	1.7
CRANE HIGH SCHOOL	DORMS	DORM 16	9545428	12/8/2020	Detector Kit	2.5
CRANE HIGH SCHOOL	DORMS	DORM ROOM 15 A	9545431	12/8/2020	Duplicate	1.4
CRANE HIGH SCHOOL	DORMS	PATRONS ROOM A	9545456	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	DORMS	DORM 8	9545461	12/8/2020	Detector Kit	1
CRANE HIGH SCHOOL	DORMS	DORM 7	9545462	12/8/2020	Detector Kit	1.1
CRANE HIGH SCHOOL	DORMS	DORM 8B	9545465	12/8/2020	Blank	0.3
CRANE HIGH SCHOOL	DORMS	PATRONS ROOM D1	9545472	12/8/2020	Detector Kit	1.1
CRANE HIGH SCHOOL	DORMS	DORM 3	9545477	12/8/2020	Duplicate	1.4
CRANE HIGH SCHOOL	DORMS	DORM 3 D2	9545478	12/8/2020	Duplicate	1.3
CRANE HIGH SCHOOL	DORMS	DORM 4	9545479	12/8/2020	Detector Kit	1.1
CRANE HIGH SCHOOL	DORMS	DORM 5	9545480	12/8/2020	Detector Kit	2.2
CRANE HIGH SCHOOL	DORMS	DORM 2	9545481	12/8/2020	Detector Kit	1
CRANE HIGH SCHOOL	DORMS	DORM 1	9545482	12/8/2020	Detector Kit	2
CRANE HIGH SCHOOL	DORMS	LOUNGE	9545487	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	DORMS	DORM 6D3	9545491	12/8/2020	Duplicate	1.8
CRANE HIGH SCHOOL	DORMS	OFFICE 1	9545492	12/8/2020	Detector Kit	0.6
CRANE HIGH SCHOOL	DORMS	CAFETERIA 1	9545493	12/8/2020	Detector Kit	0.8
CRANE HIGH SCHOOL	DORMS	CAFETERIA 2	9545494	12/8/2020	Detector Kit	0.3

CRANE HIGH SCHOOL	DORMS	DORM 6	9545495	12/8/2020	Duplicate	1.9
CRANE HIGH SCHOOL	DORMS	CAFETERIA B1	9545496	12/8/2020	Blank	0.3
CRANE HIGH SCHOOL	DORMS	DORM 18	9545677	12/8/2020	Detector Kit	2.1
CRANE HIGH SCHOOL	DORMS	DORM 12	9545678	12/8/2020	Detector Kit	1
CRANE HIGH SCHOOL	DORMS	DORM 9	9545679	12/8/2020	Detector Kit	0.5
CRANE HIGH SCHOOL	DORMS	KITCHEN OFFICE	9545683	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	DORMS	KITCHEN	9545684	12/8/2020	Detector Kit	1.1
CRANE HIGH SCHOOL	DORMS	14	9545685	12/8/2020	Detector Kit	1.5
CRANE HIGH SCHOOL	DORMS	DORM 10	9545687	12/8/2020	Duplicate	1.8
CRANE HIGH SCHOOL	DORMS	BREEZEWAY	9545689	12/8/2020	Detector Kit	0.6
CRANE HIGH SCHOOL	DORMS	DORM 10A	9545692	12/8/2020	Duplicate	1.5
CRANE HIGH SCHOOL	GYM	GYM 1	9545467	12/8/2020	Detector Kit	1.3
CRANE HIGH SCHOOL	GYM	GYM 2	9545468	12/8/2020	Detector Kit	1.1
CRANE HIGH SCHOOL	GYM	GYM 4	9545485	12/8/2020	Detector Kit	1
CRANE HIGH SCHOOL	GYM	BOYS LOCKER ROOM	9545500	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	GYM	BOYS LOCKER ROOM D	9545608	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	GYM	GYM 3	9545663	12/8/2020	Detector Kit	1
CRANE HIGH SCHOOL	GYM	GIRLS LOCKER ROOM	9545696	12/8/2020	Detector Kit	1.2
CRANE HIGH SCHOOL	GYM	GIRLS LOCKER ROOM OF	9545697	12/8/2020	Blank	0.3
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 8	9545311	12/8/2020	Duplicate	0.9
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 4	9545326	12/8/2020	Duplicate	2
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 4D2	9545442	12/8/2020	Duplicate	1.4
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 5	9545474	12/8/2020	Duplicate	2
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 2	9545484	12/8/2020	Detector Kit	2
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 7	9545497	12/8/2020	Detector Kit	1.5
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 7B1	9545499	12/8/2020	Blank	0.3
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 9	9545606	12/8/2020	Detector Kit	1.6
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 8D1	9545668	12/8/2020	Duplicate	1.2
CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 6	9545676	12/8/2020	Detector Kit	1.7
CRANE HIGH SCHOOL	HIGH SCHOOL	FAX ROOM	9545432	12/8/2020	Duplicate	1.2
CRANE HIGH SCHOOL	HIGH SCHOOL	P OFFICE LOUNGE	9545433	12/8/2020	Detector Kit	1.3
CRANE HIGH SCHOOL	HIGH SCHOOL	P OFFICE	9545434	12/8/2020	Detector Kit	2
CRANE HIGH SCHOOL	HIGH SCHOOL	FRONT OFFICE	9545435	12/8/2020	Detector Kit	1.9
CRANE HIGH SCHOOL	HIGH SCHOOL	TEACHER LOUNGE	9545436	12/8/2020	Detector Kit	1.4

CRANE HIGH SCHOOL	HIGH SCHOOL	ROOM 1 TECH LAB	9545437	12/8/2020	Blank	1.3
CRANE HIGH SCHOOL	HIGH SCHOOL	TECH LAB OFFICE	9545438	12/8/2020	Detector Kit	0.3
CRANE HIGH SCHOOL	HIGH SCHOOL	COPY ROOM	9545439	12/8/2020	Duplicate	1.5
CRANE HIGH SCHOOL	HIGH SCHOOL	CLASS 5	9545440	12/8/2020	Duplicate	2
CRANE HIGH SCHOOL	HIGH SCHOOL	LIBRARY	9545686	12/8/2020	Detector Kit	2.1
CRANE HIGH SCHOOL	TEACHERAGE 1	TEACHERAGE B	9538374	12/8/2020	Detector Kit	1.3
CRANE HIGH SCHOOL	TEACHERAGE 1	TEACHERAGE A	9545415	12/8/2020	Detector Kit	1.4
CRANE HIGH SCHOOL	TEACHERAGE 2	TEACHERAGE D	9545457	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	TEACHERAGE 2	TEACHERAGE C	9545469	12/8/2020	Detector Kit	0.9
CRANE HIGH SCHOOL	TEACHERAGE 3	TEACHERAGE F	9545446	12/8/2020	Detector Kit	1.5
CRANE HIGH SCHOOL	TEACHERAGE 3	TEACHERAGE G	9545454	12/8/2020	Detector Kit	0.6
CRANE HIGH SCHOOL	TEACHERAGE 3	TEACHERAGE E	9545490	12/8/2020	Detector Kit	1.9
CRANE HIGH SCHOOL	TEACHERAGE 4	TEACHERAGE H	9545471	12/8/2020	Detector Kit	1.1
CRANE HIGH SCHOOL	TEACHERAGE 5	TEACHERAGE I	9545458	12/8/2020	Detector Kit	1.5
CRANE HIGH SCHOOL	TEACHERAGE 6	TEACHERAGE J	9545652	12/8/2020	Detector Kit	1.2
CRANE HIGH SCHOOL	WRESTLING	WRESTLING ROOM	9545664	12/8/2020	Detector Kit	0.3
CRANE HIGH SCHOOL					Spike	27.6
CRANE HIGH SCHOOL					Spike	27.5
CRANE HIGH SCHOOL					Spike	29.8

- *The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.*
- [3 number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.